



- LEGEND:**
- SITE BOUNDARY
 - - - EXISTING WATERMAIN
 - PROPOSED WATERMAIN
 - PROPOSED HYDRANT
 - PROPOSED SLUICE VALVE
 - PROPOSED WATER METER
 - PROPOSED WATERMAIN UNDER CONSTRUCTION BY OTHERS. REF: SD178/0007
 - PROPOSED ROAD UNDER CONSTRUCTION BY OTHERS. REF: SD178/0007
- NOTE:**
- ALL PIPE WORK, VALVES, CHAMBERS, NETWORK ARRANGEMENTS AND ALL ASSOCIATED WATERMAIN WORKS TO COMPLY WITH THE IRISH WATER INFRASTRUCTURE STANDARD DETAILS.
 - ALL NEW WATERMAIN MATERIAL SHALL BE IN ACCORDANCE WITH SECTION 3.9 OF THE IRISH WATER CODE OF PRACTICE
 - ALL PIPE WORK, VALVES, CHAMBERS, NETWORK ARRANGEMENTS AND ALL ASSOCIATED WATERMAIN WORKS TO BE IN ACCORDANCE WITH IRISH WATER CODES OF PRACTICE AND STANDARD DETAILS.
 - AIR PRESSURE TESTS TO ALL WORKS TO BE TAKEN IN CHARGE TO IRISH WATER CODE OF PRACTICE SECTION 4.10.
 - METERS FOR APARTMENTS AND SIMILAR PROPERTIES WILL BE INSTALLED INTERNALLY WITHIN THE PREMISES IN ACCORDANCE WITH THE BUILDING CONTROL AUTHORITY'S REQUIREMENTS AND SUBJECT TO REVIEW BY IRISH WATER. SEE SECTION OF WATER CODE OF PRACTICE 3.10.2. PLEASE NOTE THAT IRISH WATER WOULD NOT ENTER THE PRIVATE SIDE TO TAKE READINGS, READINGS WOULD BE TAKEN BY THE MANAGEMENT COMPANY FOR EACH APARTMENT. IRISH WATER WOULD MONITOR OVERALL USAGE FROM THE BULK METER AND NOTIFY THE MANAGEMENT COMPANY.
 - THE PROPOSED 150mm WATERMANS WILL BE LOCATED A MINIMUM OF 300mm FROM THE WASTEWATER INFRASTRUCTURE IN ACCORDANCE WITH SECTION 3.5.18 OF THE IRISH WATER WASTEWATER CODE OF PRACTICE.

PROPOSED WATERMAIN LAYOUT.
SCALE= 1:200

PLANNING DRAWING.
NOT FOR CONSTRUCTION.
ALL LEVELS GIVEN ARE
RELATIVE TO ORDNANCE DATUM.
THIS DRAWING HAS BEEN ISSUED FOR INFORMATION
PURPOSES ONLY AND MUST NOT BE USED
FOR CONSTRUCTION UNDER ANY CIRCUMSTANCES

- NOTES**
- For setting out refer to Architect's drawings.
 - This drawing to be read in conjunction with all other Architectural and Engineering drawings and all other relevant drawings and Specifications.
 - DO NOT SCALE THIS DRAWING. Use figured dimensions only.
 - No part of this document may be reproduced or transmitted in any form or stored in any retrieval system of any nature without the written permission as copyright holder except as agreed for use on the project for which the document was originally issued.
 - Ordnance Survey Ireland Licence Number EN 0074020

Rev. No.	Date	REVISION NOTE	Drn. By	Chkd. By

Architect	Coady Architects			
Project	Belgard Square North Tallaght			
Title	Proposed Watermain Layout Sheet 2 Of 2			
Dwg. No.	TAL-CSC-ZZ-XX-DR-C-0006			
Date	Drn. by	Chkd. by	Scale	Revision
28.04.2020	AB	GS	NB 1:200 @A1	

CS Consulting Group
DUBLIN | LONDON | LIMERICK

Head Office
19-22 Dame Street, Dublin 2.
T: +353 (0)1 5480863 F: +353 (0)1 9011355
e: info@csconsulting.ie
w: www.csconsulting.ie

Quality Environment I.S. EN ISO 9001:2008
NSAI Certified Energy I.S. EN ISO 14001:2004
Health & Safety OHSAS 18001:2007